CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

TINE ENGINEERING - BOILDING WATERIALS EISTING TH

LISTING SERVICE

LISTING No. 3225-0273:104 Page 1 of 1

CATEGORY: Fire Dampers

LISTEE: United Air, PO Box 40913, Nashville TN 37204

Contact: *Jon Newnam (615) 256-3500

DESIGN: Models U-305 and U-315 curtain type fire dampers. No. 18 to 22 Ga. galvanized steel

frame, No. 22 Ga. galvanized steel blades construction. Refer to listee's data sheet for

additional detailed product description and operational considerations.

Model	Single Section		Multip	Multiple Assemblies	
	Width	<u>Height</u>	<u>Width</u>	<u>Height</u>	
U-305	36"	36"	NA	NA	
U-315	48"	48"	96"	48"	

RATING: 1-1/2 Hour

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, classification and UL label.

APPROVAL: Listed as fire dampers for use in heating, ventilating and air conditioning duct systems

passing through fire resistive walls, partitions or floors. Model U305 is suitable for horizontal and vertical installation. Model U-315 is suitable for vertical installation only.

NOTE: Leakage rating not evaluated. Refer to CSFM Listing Category 3230 for listed leakage

dampers.

*Rev. 06-08-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 8, 2002 Listing Expires June 30, 2003

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager